

AAON INC.

SPA# SP33102-000-05

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA  
COMPANY :  
ORIGINATOR: MATTHEW C LEEPER  
FROM : TINA MCBEATH  
JOBNAME :  
ISSUE DATE: 1/29/2025

----- [ SOI TEXT ] -----

RQ/RN/RZ DUAL POINT POWER: WIRING METHOD #3.  
PROVIDE GROUNDING LUGS ON BOTH CIRCUITS.

PLUS 1 WEEK LEAD TIME.

----- [ SPECIAL NOTES ] -----

\*THIS IS A LIST ADD PER UNIT.

1. OPTIONAL POWER SWITCH IF SELECTED, WILL BE WIRED TO  
1ST CIRCUIT ONLY. IF 2ND CIRCUIT POWER SWITCH IS  
REQUIRED, IT MUST BE FIELD INSTALLED.

2. WHEN PHASE & BROWN OUT PROTECTION IF SELECTED,  
WILL BE WIRED TO THE 2ND POWER CIRCUIT. IF PBO  
PROTECTION IS REQUIRED FOR THE 1ST CIRCUIT, YOU MUST  
OBTAIN AN ADDITIONAL SPA.

3. ECAT RATING SHEET DOES NOT REFLECT DUAL POINT POWER  
WIRING.

4. SIZE POWER SWITCH TO MATCH MOP OF 1ST CIRCUIT

----- [ DESCRIPTION ] -----

RQ/RN/RZ DUAL POINT POWER - WIRING METHOD #3.

1ST CIRCUIT POWERS: COMPRESSORS, CONDENSER FAN(S),  
OPTIONAL HEAT WHEEL(S), OPTIONAL EXHAUST/RETURN  
FAN(S), OPTIONAL HEAT.

2ND CIRCUIT POWERS: SUPPLY FAN(S) AND CONTROLS

OPTIONAL POWER SWITCH WILL BE RESIZED FOR FIRST CIRCUIT  
MOP.

PROVIDE GROUNDING LUGS ON BOTH CIRCUITS. (MUST SHOW  
THESE ON THE UNIT'S ELECTRICAL DRAWING).

Model	Required Features	List Price
_____	_____	_____

**AAON INC.**

**SPA# SP33102-000-05**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEBSITE SPA  
COMPANY :  
ORIGINATOR: MATTHEW C LEEPER  
FROM : TINA MCBEATH  
JOBNAME :  
ISSUE DATE: 1/29/2025

| GS-RN | 37=X/Y/1-8 | \$3,158.00 |

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.