

AAON INC.

SPA# SP35075-000-04

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA
COMPANY :
ORIGINATOR: TINA MCBEATH
FROM : TINA MCBEATH
JOBNAME :
ISSUE DATE: 1/29/2025

----- [SOI TEXT] -----

RQ/RN/RZ DUAL POINT POWER (WIRING METHOD #2)
PROVIDE GROUNDING LUGS ON BOTH CIRCUITS.

PLUS 1 WEEK LEAD TIME.

----- [SPECIAL NOTES] -----

THIS IS A LIST ADD PER UNIT.

1. OPTIONAL POWER SWITCH IF SELECTED, WILL BE WIRED TO
1ST CIRCUIT ONLY. IF 2ND CIRCUIT POWER SWITCH IS
REQUIRED, IT MUST BE FIELD INSTALLED.

2. WHEN PHASE & BROWN OUT PROTECTION IF SELECTED,
WILL BE WIRED TO THE 2ND POWER CIRCUIT. IF PBO
PROTECTION IS REQUIRED FOR THE 1ST CIRCUIT, YOU MUST
OBTAIN AN ADDITIONAL SPA.

3. ECAT RATING SHEET DOES NOT REFLECT DUAL POINT POWER
WIRING.

4. SIZE POWER SWITCH TO MATCH MOP OF 1ST CIRCUIT

----- [DESCRIPTION] -----

RQ/RN/RZ DUAL POINT POWER - WIRING METHOD #2.

1ST CIRCUIT POWERS COMPRESSORS & CONDENSER FANS.

2ND CIRCUIT POWERS SUPPLY FAN, CONTROLS, (OPTIONAL)
EXHAUST/RETURN FANS, (OPTIONAL) HEAT, (OPTIONAL) HEAT
WHEEL & PHASE & BROWN OUT PROTECTION IF ORDERED.

OPTIONAL POWER SWITCH WILL BE RESIZED FOR FIRST CIRCUIT
MOP

PROVIDE GROUNDING LUGS ON BOTH CIRCUITS. (MUST SHOW
THESE ON THE UNIT'S ELECTRICAL DRAWING).

Model	Required Features	List Price
_____	_____	_____

AAON INC.

SPA# SP35075-000-04

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA
COMPANY :
ORIGINATOR: TINA MCBEATH
FROM : TINA MCBEATH
JOBNAME :
ISSUE DATE: 1/29/2025

| GS-RN | 37=X/Y/1-8 | \$3,158.00 |

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.