

AAON INC.

SPA# SP35348-000-03

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA  
COMPANY :  
ORIGINATOR: LARRY HONEL  
FROM : TINA MCBEATH  
JOBNAME :  
ISSUE DATE: 4/29/2025

----- [ SOI TEXT ] -----

SMOKE PURGE SEQUENCE II.

----- [ SPECIAL NOTES ] -----

- \* THIS PRICE IS PER UNIT, VALID FOR RQ, RN, & RL UNITS.
- \* SPA NOT VALID IF UNIT HAS VCCX CONTROL OPTION.
- \* ELECTRICAL DRAFTING: PLEASE WORK WITH PRODUCT ENGINEERING AND CONTROLS.

----- [ DESCRIPTION ] -----

SMOKE PURGE SEQUENCE II.

- UPON A REMOTE CONTACT CLOSURE:
- THE ECON O/A DAMPERS FULLY OPEN
- THE R/A DAMPERS CLOSE,
- THE SUPPLY FAN AND EXHAUST FANS ARE ENERGIZED. ALL OTHER FUCTIONS ARE DISABLED.
- USE BELIMO ACTUATOR

\*\*\*FROM FACTORY, AAON MUST WIRE THE UNIT SO THAT THE A2L MITIGATION SEQUENCE WILL TAKE PRIORITY OF THIS SMOKE PURGE SEQUENCE. IT IS UP TO LOCAL CODE AND THE AUTHORITY HAVING JURISDICTION TO DECIDE IF THE SMOKE PURGE SEQUENCE NEEDS TO TAKE PRIORITY OF THE A2L MITIGATION SEQUENCE. A JUMPER WIRE WILL NEED TO BE ADDED IN THE FIELD TO ALLOW FOR SMOKE PURGE OPERATION. WHEN SMOKE PURGE IS IN OPERATION,ALL OTHER SAFETIES ARE DISABLED.\*\*\*

Model	Required Features	List Price
GS-RN	VCCX & 37=X/Y/1-8	\$1,974.00

**AAON INC.**

**SPA# SP35348-000-03**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEBSITE SPA  
COMPANY :  
ORIGINATOR: LARRY HONEL  
FROM : TINA MCBEATH  
JOBNAME :  
ISSUE DATE: 4/29/2025

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.