

AAON INC.

SPA# SP35429-000-03

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA  
COMPANY :  
ORIGINATOR: HEIDI-EG  
FROM : TINA MCBEATH  
JOBNAME :  
ISSUE DATE: 1/30/2025

----- [ SOI TEXT ] -----

SMOKE PURGE SEQUENCE I (WITH VCCX CONTROLS)

----- [ SPECIAL NOTES ] -----

\*SPA ONLY VALID IF VCCX CONTROLS ARE SELECTED.

\*SPA VALID FOR RQ, RN, & RZ UNITS.

----- [ DESCRIPTION ] -----

SPECIAL SMOKE PURGE SEQUENCE 1 WITH VCCX CONTROLS

- UPON A REMOTE SMOKE PURGE CONTACT CLOSURE, THE CONTROLLER WILL BE OVERRIDDEN AND AAON WILL PROVIDE RELAY LOGIC TO DO THE FOLLOWING:
- FORCE THE O/A DAMPER ACTUATOR TO THE FULL OPEN POSITION,
- FORCE THE R/A DAMPER ACTUATOR TO THE FULL CLOSED POSITION
- ENERGIZE THE EXHAUST/RETURN FAN ALL OTHER FUNCTIONS ARE DISABLED.

USE BELIMO ACTUATOR.

Model	Required Features	List Price
GS-RN	VCCX & 37=X/Y/1-8	\$1,974.00

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.