

AAON INC.

SPA# SV00081-000-10

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

## GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB  
COMPANY :  
ORIGINATOR: CP-BRIAN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/19/2025

----- [ SOI TEXT ] -----

FACTORY INSTALLED GFI CONVENIENCE OUTLET W/ TRANSFORMER

LEAD TIME ADD = NONE

----- [ SPECIAL NOTES ] -----

THIS SPA MAY BE APPLIED TO ANY H3, V3, SB, OR M2 UNIT.

THIS SPA MAY NOT BE APPLIED TO A H3/V3 UNIT WITH A  
SMALL EXTERNAL CONTROL PANEL.

----- [ DESCRIPTION ] -----

FACTORY WIRED GFI CONVENIENCE OUTLET W/ TRANSFORMER

PROVIDE A GFI CONVENIENCE OUTLET IN THE UNIT CONTROL  
PANEL, WIRED TO A FACTORY INSTALLED TRANSFORMER.

IF SELECTED WITH A MEDIUM EXTERNAL CONTROL BOX, PROVIDE  
AN EXTENDED CONTROL BOX (B300-700-500).

IF SELECTED WITH A LARGE EXTERNAL CONTROL BOX, NO  
CONTROL BOX SIZE CHANGES REQUIRED.

IF SELECTED WITH H3/V3 INTERNAL CONTROL PANEL, OUTLET  
SHALL BE INSTALLED ON THE SIDE OF THE PANEL.  
TRANSFORMER MAY BE INSTALLED IN COIL SECTION OR BLOWER  
SECTION AS REQUIRED.

IF A FACTORY INSTALLED NON-FUSED DISCONNECT IS  
SELECTED, THE PRIMARY LEADS OF THE TRANSFORMER WILL BE  
WIRED TO THE LINE SIDE OF THE DISCONNECT SO THAT THE  
OUTLET WILL BE OPERATIONAL EVEN WHEN THE UNIT IS TURNED  
OFF.

IF NO FACTORY INSTALLED DISCONNECT IS SELECTED, THE  
TRANSFORMER WILL BE WIRED TO THE MAIN POWER BLOCK.

Model	Required Features	List Price
GS-ALL	TYPE/SPECIAL=X	\$2526

**AAON INC.**

**SPA# SV00081-000-10**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: CP-BRIAN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/19/2025

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.