

AAON INC.

SPA# SV04097-000-05

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB  
COMPANY :  
ORIGINATOR: CP-BRIAN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

----- [ SOI TEXT ] -----

H3/V3/M2 OPPOSITE ACCESS SIDE COIL CONNECTIONS  
- NO DX COIL

----- [ SPECIAL NOTES ] -----

UNIT HANDEDNESS MUST BE SELECTED AS PRIMARY  
SERVICE/FILTER ACCESS.

THIS SPA MAY BE APPLIED TO ANY H3/V3/M2 CABINET SIZE.  
THIS SPA IS NOT ALLOWED WITH DX SPLIT SYSTEMS.

SERVICE CLEARANCE IS REQUIRED ON THE SIDE OPPOSITE  
ACCESS.

- FOR H3/V3 UNITS THE COIL SERVICE ACCESS IS ON THE  
CONFIGURED ACCESS SIDE.
- FOR M2 UNITS THE COIL SERVICE ACCESS IS ON THE  
OPPOSITE ACCESS SIDE ALONG WITH THE COIL CONNECTIONS.

DRAIN PAN CONNECTION SHALL EXIT THE UNIT ON THE  
CONFIGURED ACCESS SIDE.

----- [ DESCRIPTION ] -----

H3/V3/M2 OPPOSITE HAND CONNECTIONS  
COIL CONNECTIONS, NO DX COIL

ALL COIL CONNECTIONS IN THE MAIN COIL SECTION OR M2  
SECTION WHERE THE SPA IS APPLIED WILL EXIT THE UNIT  
OPPOSITE THE CONFIGURED ACCESS SIDE.

CONDENSATE DRAIN CONNECTION REMAINS ON  
PRIMARY/CONFIGURED ACCESS SIDE.

SEE PRODUCT MANAGER FOR COIL SPECIFICATION

Model	Required Features	List Price
GS-ALL	FEATURE23=X	\$2375

The expiration date for this SPA is 1/31/2026

**AAON INC.**

**SPA# SV04097-000-05**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: CP-BRIAN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.