

AAON INC.

SPA# SV04100-000-04

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: CP-BRIAN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

----- [SOI TEXT] -----

H3/V3/M2 OPPOSITE ACCESS SIDE COIL + DRAIN CONNECTIONS
CONFIGURED DX COIL

----- [SPECIAL NOTES] -----

UNIT HANDEDNESS MUST BE SELECTED AS PRIMARY
SERVICE/FILTER ACCESS.

THIS SPA MAY BE APPLIED TO ANY H3/V3/M2 CABINET SIZE.
THIS SPA IS ONLY INTENDED FOR USE WITH DX SPLIT
SYSTEMS.

SERVICE CLEARANCE IS REQUIRED ON THE SIDE OPPOSITE
ACCESS.

- FOR H3/V3 UNITS THE COIL PULL ACCESS IS ON THE
CONFIGURED ACCESS SIDE.
- FOR M2 UNITS THE COIL PULL AND SERVICE ACCESS IS ON
THE OPPOSITE ACCESS SIDE ALONG WITH THE COIL
CONNECTIONS.

----- [DESCRIPTION] -----

H3/V3/M2 OPPOSITE HAND CONNECTIONS
COIL + DRAIN PAN CONNECTIONS, W/ DX COIL

ALL COIL CONNECTIONS AND CONDENSATE DRAIN PAN
CONNECTIONS IN THE MAIN COIL SECTION OR M2
SECTION WHERE THE SPA IS APPLIED WILL EXIT THE
UNIT OPPOSITE THE CONFIGURED ACCESS SIDE.

A REMOVABLE PANEL SHALL BE INSTALLED ON THE SIDE
OPPOSITE CONFIGURED HANDEDNESS IN H3/V3 UNITS TO ALLOW
SERVICE ACCESS TO THE EXPANSION VALVES.

SEE PRODUCT MANAGER FOR COIL SPECIFICATION.

Model	Required Features	List Price
GS-ALL	FEATURE23=X	\$4125

AAON INC.

SPA# SV04100-000-04

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: CP-BRIAN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.