

**AAON INC.**

2425 S. YUKON AVE.  
TULSA, OK 74107

**SPA# SV05912-000-05**

Ph. 918-583-2266  
Fax 918-382-6369

## GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB  
COMPANY :  
ORIGINATOR: JOHN G GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

----- [ SOI TEXT ] -----

H3/V3: FACTORY INSTALLED 60A NON-FUSED DISCONNECT  
EXTERNAL CONTROL BOX

### REQUIREMENTS:

UNIT CANNOT BE CONFIGURED WITH INTERNAL CONTROL BOX

----- [ SPECIAL NOTES ] -----

THIS SPA MAY BE ONLY APPLIED TO AN H3/V3 UNIT  
CONFIGURED WITH A MEDIUM EXTERNAL CONTROL  
BOX (F15 = B).

THE DISCONNECT STICKS OUT ~5" FROM THE CONTROL PANEL.  
36" OF CLEARANCE ARE REQUIRED FROM THE FACE OF THE  
DISCONNECT. TOTAL CONTROL PANEL CLEARANCE  
SHOULD BE 41". REFER TO IOM FOR CLEARANCE  
REQUIREMENTS FOR OTHER SIDES OF UNIT.

IF AN INTERNAL CONTROL BOX IS SELECTED, THIS SPA IS NOT  
APPLICABLE.

UNIT MOP MUST BE LESS THAN OR EQUAL TO 60 AMPS.

SEE ATTACHED CUT SHEET OF SPECIAL CONTROL BOX FOR  
DETAILS.

TO ORDER A DISCONNECT FOR FIELD INSTALL CONTACT THE  
AAON PARTS DEPARTMENT AND ASK TO ORDER LONGVIEW PART  
NUMBER 27894 (NEMA 1 60A DISC)

----- [ DESCRIPTION ] -----

H3/V3: FACTORY INSTALLED 60A NON-FUSED DISCONNECT  
EXTERNAL CONTROL BOX

### \*\*\*GENERAL\*\*\*

DISCONNECT WILL BE INSTALLED ON A MEDIUM EXTENDED  
EXTERNAL CONTROL PANEL (ASSY B300-700-500). A  
LENGTH OF 6 FOOT FLEXIBLE CONDUIT WILL CONNECT THE  
EXTERNAL CONTROL PANEL TO THE AIR HANDLING UNIT.

NEW CONTROL PANEL DIMENSIONS ARE 36" (L) X 22" (H) X

**AAON INC.**

**SPA# SV05912-000-05**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: JOHN G GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

11" (W)

**\*\*\*ELECTRICAL\*\*\***

ADD THE FOLLOWING DISCONNECT TO THE UNIT AND SHOW ON  
THE UNIT WIRING DIAGRAM:

ACP # 27894

**\*\*\*MECHANICAL & BOM\*\*\***

ENSURE THAT COMPONENTS FOR PART B300-700-500 ARE USED  
IN PLACE OF THE CONFIGURED EXTERNAL CONTROL PANEL.

Model	Required Features	List Price
GS-ALL	NOT VALID W/ INTERNAL CONTROL PANEL	\$5,976

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.