

AAON INC.

SPA# SV05920-000-05

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

----- [SOI TEXT] -----

H3/V3: FACTORY INSTALLED 30A NON-FUSED DISCONNECT
EXTERNAL CONTROL BOX

REQUIREMENTS:

UNIT CANNOT BE CONFIGURED WITH INTERNAL CONTROL BOX

----- [SPECIAL NOTES] -----

THIS SPA MAY BE ONLY APPLIED TO AN H3/V3 UNIT
CONFIGURED WITH MEDIUM EXTERNAL CONTROL
BOX (F15 = B).

THE DISCONNECT STICKS OUT ~4" FROM THE CONTROL
PANEL. 36" OF CLEARANCE ARE REQUIRED FROM THE FACE OF
THE DISCONNECT. TOTAL CONTROL PANEL CLEARANCE SHOULD
BE 40". REFER TO IOM FOR CLEARANCE REQUIREMENTS FOR
OTHER SIDES OF UNIT.

IF AN INTERNAL CONTROL BOX IS SELECTED, THIS SPA IS NOT
APPLICABLE.

UNIT MOP MUST BE LESS THAN OR EQUAL TO DISCONNECT SIZE.

SEE ATTACHED CUT SHEET OF SPECIAL CONTROL BOX FOR
DETAILS. THE EXTERNAL CONTROL PANEL DIMENSIONS ARE
22.2"H X 36.0"L X 11.0"D

TO ORDER A DISCONNECT FOR FIELD INSTALL CONTACT THE
AAON PARTS DEPARTMENT AND ASK TO ORDER LONGVIEW PART
NUMBER 27892 (NEMA 1 30A DISC)

----- [DESCRIPTION] -----

H3/V3: FACTORY INSTALLED 30A NON-FUSED DISCONNECT
EXTERNAL CONTROL BOX

*****GENERAL*****

DISCONNECT WILL BE INSTALLED IN A MEDIUM EXTENDED
EXTERNAL CONTROL PANEL (ASSY B300-700-500). A
LENGTH OF 6 FOOT FLEXIBLE CONDUIT WILL CONNECT THE
EXTERNAL CONTROL PANEL TO THE AIR HANDLING UNIT.

AAON INC.

SPA# SV05920-000-05

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

NEW CONTROL PANEL DIMENSIONS ARE 36" (L) X 22" (H) X
11" (W)

*****ELECTRICAL*****

ADD THE FOLLOWING DISCONNECT TO THE UNIT AND SHOW ON
THE UNIT WIRING DIAGRAM.

ACP # 27892

*****MECHANICAL & BOM*****

ENSURE THAT COMPONENTS FOR ASSEMBLY B300-700-500 ARE
USED IN PLACE OF THE CONFIGURED EXTERNAL CONTROL PANEL.

Model	Required Features	List Price
GS-H3	NOT VALID W/ INTERNAL CONTROL PANEL	\$5,041

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.