

**AAON INC.**

2425 S. YUKON AVE.  
TULSA, OK 74107

**SPA# SV05934-000-05**

Ph. 918-583-2266  
Fax 918-382-6369

**SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: RACHEL MARIE GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

----- [ SOI TEXT ] -----

V3 FACTORY INSTALLED 60A NON-FUSED DISCONNECT INDOOR  
FRONT (OPPOSITE RETURN AIR OPENING)

LEAD TIME ADD = NONE

----- [ SPECIAL NOTES ] -----

THIS IS A 60AMP NEMA 1 NON-FUSED DISCONNECT

NOT VALID FOR SB UNITS. V3 UNIT MUST HAVE INTERNAL  
CONTROL PANEL.

THE DISCONNECT STICKS OUT ~5" FROM THE CABINET. 36" OF  
CLEARANCE ARE REQUIRED FROM THE FACE OF THE  
DISCONNECT. TOTAL FRONT CLEARANCE SHOULD BE  
41". REFER TO IOM FOR CLEARANCE REQUIREMENTS FOR OTHER  
SIDES OF UNIT.

DISCONNECT MAY BLOCK FAN ACCESS FROM THE FRONT  
(OPPOSITE INTAKE SIDE) OF THE UNIT. ALTERNATE FAN  
ACCESS LOCATION REQUIRED.

UNIT MOP MUST BE LESS THAN OR EQUAL TO DISCONNECT SIZE.

TO ORDER A DISCONNECT FOR FIELD INSTALL CONTACT THE  
AAON PARTS DEPARTMENT AND ASK TO ORDER LONGVIEW PART  
NUMBER 27894.

----- [ DESCRIPTION ] -----

V3: FACTORY INSTALLED 60A NON-FUSED DISCONNECT INDOOR  
FRONT

ACP # 27894

\*\*\*MECHANICAL\*\*\*

MOUNT THE DISCONNECT ON THE FRONT OF THE V3 UNIT,  
ON THE FAN SECTION NEAR THE ACCESS SIDE OF THE UNIT.

\*\*\*ELECTRICAL & WIRING\*\*\*

WIRE THE DISCONNECT TO THE UNIT POWER BLOCK WITH THE  
WIRE GAUGE SHOWN ON THE WIRING DIAGRAM.

**AAON INC.**

**SPA# SV05934-000-05**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: RACHEL MARIE GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

A 41" CLEARANCE IS REQUIRED ON THE DISCONNECT SIDE OF  
THE UNIT. THIS MUST BE ACCOUNTED FOR IN THE NAMEPLATE.  
IF THE NAMEPLATE CLEARANCE IS LARGER THAN 41" OR  
"DUCT", NO NAMEPLATE MODIFICATION IS NEEDED.

Model	Required Features	List Price
V3	NOT VALID W/ EXTERNAL CONTROL PANEL	\$5,976

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.