AAON INC.

## SPA# SV05937-000-06

2425 S. YUKON AVE. TULSA, OK 74107 Ph. 918-583-2266 Fax 918-382-6369

## SPECIAL PRICING AUTHORIZATION

TO	:	WEB

COMPANY

ORIGINATOR: RACHEL MARIE GRUNDMANN

FROM : PEYTON PATTERSON

JOBNAME

ISSUE DATE: 2/14/2025

----- [ SOI TEXT ] ------

V3 FACTORY INSTALLED 100A NON-FUSED DISCONNECT INDOOR

FRONT

LEAD TIME ADD = NONE

----- [ SPECIAL NOTES ] ------

THIS IS A 100AMP NEMA 1 NON-FUSED DISCONNECT

NOT VALID WITH SB. V3 MUST HAVE INTERNAL CONTROL PANEL.

THE DISCONNECT STICKS OUT ~5" FROM THE CABINET. 36" OF CLEARANCE ARE REQUIRED FROM THE FACE OF THE DISCONNECT. TOTAL FRONT CLEARANCE SHOULD BE 41". REFER TO IOM FOR CLEARANCE REQUIREMENTS FOR OTHER SIDES OF UNIT.

DISCONNECT MAY BLOCK FAN ACCESS FROM THE FRONT (OPPOSITE INTAKE SIDE) OF THE UNIT. ALTERNATE FAN ACCESS LOCATION REQUIRED.

UNIT MOP MUST BE LESS THAN OR EQUAL TO DISCONNECT SIZE.

TO ORDER A DISCONNECT FOR FIELD INSTALL, CONTACT THE AAON PARTS DEPARTMENT AND ASK TO ORDER LONGVIEW PART NUMBER 27897 .

----- [ DESCRIPTION ] -----

V3: FACTORY INSTALLED 100A NON-FUSED DISCONNECT INDOOR FRONT

ACP # 27897

#### \*\*\*MECHANICAL\*\*\*

MOUNT THE DISCONNECT ON THE FRONT OF THE V3 UNIT, WHICH IS THE WALL OPPOSITE THE RETURN AIR OPENING. THE FRONT WALL HAS NO OPENINGS.

SPA CANNOT BE USED WITH SB.

# AAON INC.

## SPA# SV05937-000-06

2425 S. YUKON AVE. TULSA, OK 74107 Ph. 918-583-2266 Fax 918-382-6369

## SPECIAL PRICING AUTHORIZATION

TO : WEB

COMPANY

ORIGINATOR: RACHEL MARIE GRUNDMANN

FROM : PEYTON PATTERSON

JOBNAME

ISSUE DATE: 2/14/2025

\*\*\*ELECTRICAL & WIRING\*\*\*

WIRE THE DISCONNECT TO THE UNIT POWER BLOCK WITH THE

WIRE GAUGE SHOWN ON THE WIRING DIAGRAM

A 41" CLEARANCE IS REQUIRED ON THE DISCONNECT SIDE OF THE UNIT. THIS MUST BE ACCOUNTED FOR IN THE NAMEPLATE. IF THE NAMEPLATE CLEARANCE IS LARGER THAN 41" OR DUCT, NO NAMEPLATE MODIFICATION IS NEEDED.

١	Model	-	Required Features		List Price	ı
١		_ [				_
١	V3	_ [	NOT VALID W/ EXTERNAL CONTROL PANEL	1	\$6,769	Ī

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.