

**AAON INC.**

2425 S. YUKON AVE.  
TULSA, OK 74107

**SPA# SV05939-000-05**

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: RACHEL MARIE GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

----- [ SOI TEXT ] -----

H3/V3/SB FACTORY INSTALLED 60A NON-FUSED DISCONNECT  
INDOOR, OPPOSITE ACCESS

LEAD TIME ADD = NONE

----- [ SPECIAL NOTES ] -----

THIS IS A 60AMP NEMA 1 NON-FUSED DISCONNECT

UNIT MOP MUST BE LESS THAN OR EQUAL TO DISCONNECT SIZE.

THE DISCONNECT STICKS OUT 5" FROM THE CABINET. 36" OF  
CLEARANCE ARE REQUIRED FROM THE FACE OF THE DISCONNECT.  
TOTAL OPPOSITE ACCESS CLEARANCE SHOULD BE 41". REFER TO  
IOM FOR CLEARANCE REQUIREMENTS FOR OTHER SIDES OF  
UNIT.

TO ORDER A DISCONNECT FOR FIELD INSTALL CONTACT THE  
AAON PARTS DEPARTMENT AND ASK TO ORDER LONGVIEW PART  
NUMBER 27894.

----- [ DESCRIPTION ] -----

H3/V3/SB FACTORY INSTALLED 60A NON-FUSED DISCONNECT  
INDOOR, OPPOSITE ACCESS

ACP # 27894

**\*\*\*MECHANICAL\*\*\***

MOUNT THE DISCONNECT ON THE SIDE OF THE V3/H3/SB UNIT  
OPPOSITE THE CONFIGURED ACCESS SIDE.

IF THE SB IS CONFIGURED AS CONDENSER ONLY (NO AIR  
TUNNEL), MOUNT THE DISCONNECT ON THE SIDE OF THE UNIT  
OPPOSITE THE CONTROL PANEL ACCESS.

**\*\*\*ELECTRICAL & WIRING\*\*\***

WIRE THE DISCONNECT TO THE UNIT POWER BLOCK  
WITH THE WIRE GAUGE SHOWN ON THE WIRING DIAGRAM.

A 41" CLEARANCE IS REQUIRED ON THE DISCONNECT SIDE OF  
THE UNIT. THIS MUST BE ACCOUNTED FOR IN THE NAMEPLATE.

**AAON INC.**

**SPA# SV05939-000-05**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEB  
COMPANY :  
ORIGINATOR: RACHEL MARIE GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/14/2025

IF THE NAMEPLATE CLEARANCE IS LARGER THAN 41" OR  
"DUCT", NO NAMEPLATE MODIFICATION IS NEEDED.

Model	Required Features	List Price
GS-ALL	NOT VALID W/ EXTERNAL CONTROL PANEL	\$5,976

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.