

AAON INC.

2425 S. YUKON AVE.
TULSA, OK 74107

SPA# SV05940-000-06

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

----- [SOI TEXT] -----

H3/V3/SB: FACTORY INSTALLED 100A NON-FUSED DISCONNECT
INDOOR, OPPOSITE ACCESS

LEAD TIME ADD = NONE

DO NOT USE WITH H3A OR H3B

----- [SPECIAL NOTES] -----

THIS IS A 100AMP NEMA 1 NON-FUSED DISCONNECT

NOT VALID WITH EXTERNAL CONTROL PANEL.
SPA CANNOT BE USED ON H3A AND H3B UNITS.

UNIT MOP MUST BE LESS THAN OR EQUAL TO DISCONNECT SIZE.

THE DISCONNECT STICKS OUT 5" FROM THE CABINET. 36" OF
CLEARANCE ARE REQUIRED FROM THE FACE OF THE DISCONNECT.
TOTAL OPPOSITE ACCESS CLEARANCE SHOULD BE 41". REFER TO
IOM FOR CLEARANCE REQUIREMENTS FOR OTHER SIDES OF
UNIT.

TO ORDER A DISCONNECT FOR FIELD INSTALL, CONTACT THE
AAON PARTS DEPARTMENT AND ASK TO ORDER LONGVIEW PART
NUMBER 27897. A 100A SHIP LOOSE DISCONNECT MAY BE USED
WITH THE H3A OR H3B.

----- [DESCRIPTION] -----

H3/V3/SB: FACTORY INSTALLED 100A NON-FUSED DISCONNECT
INDOOR, OPPOSITE ACCESS

ACP # 27897

MECHANICAL

MOUNT THE DISCONNECT ON THE SIDE OF THE V3/H3/SB UNIT
OPPOSITE THE CONFIGURED ACCESS SIDE.

IF THE SB IS CONFIGURED AS CONDENSER ONLY (NO AIR
TUNNEL), MOUNT THE DISCONNECT ON THE SIDE OF THE UNIT
OPPOSITE THE CONTROL PANEL ACCESS.

AAON INC.

SPA# SV05940-000-06

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

*****ELECTRICAL & WIRING*****

WIRE THE DISCONNECT TO THE UNIT POWER BLOCK
WITH THE WIRE GAUGE SHOWN ON THE WIRING DIAGRAM.

A 41" CLEARANCE IS REQUIRED ON THE DISCONNECT SIDE OF
THE UNIT. THIS MUST BE ACCOUNTED FOR IN THE NAMEPLATE.
IF THE NAMEPLATE CLEARANCE IS LARGER THAN 41" OR
DUCT, NO NAMEPLATE MODIFICATION IS NEEDED.

Model	Required Features	List Price
GS-ALL	NOT VALID W/ EXTERNAL CONTROL PANEL	\$6,769

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.