

AAON INC.

SPA# SV05949-000-05

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PING LIN
JOBNAME :
ISSUE DATE: 1/15/2024

----- [SOI TEXT] -----

M2: 250A NON-FUSED DISCONNECT SWITCH IN TR*
M2-18 & BOTTOM TIER M2-26, 36

REQUIRED FEATURES:
- TR* CONTROL MODULE

LEAD TIME ADD = 1 WEEK

----- [SPECIAL NOTES] -----

DISCONNECT SHALL BE WIRED FOR SINGLE POINT POWER. UNIT
MUST BE SELECTED WITH A TR* CONTROL MODULE.

UNIT MOP MUST BE LESS THAN OR EQUAL TO 250A.

THIS SPA REDUCES THE AMOUNT OF CONTROL SPACE AVAILABLE.
CONFIRM SELECTION WITH AAON APPLICATIONS IF USED WITH
ELECTRIC HEAT OR A FACTORY INSTALLED CONTROLLER.

IF MULTIPLE TR* MODULES ARE CONFIGURED, THE DISCONNECT
LOCATION SHALL AT THE DISCRETION OF ACP ENGINEERING IF
THE SPA IS NOT APPLIED TO A TR* MODULE.

THIS SPA MAY NOT BE USED FOR SIZE 26-36 TOP LEVEL TR*
MODULES.

----- [DESCRIPTION] -----

M2: 250A NON-FUSED DISCONNECT SWITCH IN TR*
M2-18 & BOTTOM TIER M2-26, 36

PROVIDE A G048730 250A DISCONNECT ASSEMBLY.

THE DISCONNECT SHALL BE INSTALLED ON THE ACCESS PANEL
OF A TR* CONTROL MODULE. DOOR & CONTROL PANEL SIZE
SHALL BE REDUCED TO ACCOMMODATE THE DISCONNECT.

THE DISCONNECT SHALL BE INSTALLED NEAR THE TOP OF THE
MODULE IF USED WITH A LOWER LEVEL MODULE, OR NEAR THE
BOTTOM IF USED WITH AN UPPER LEVEL MODULE.

Model	Required Features	List Price
-------	-------------------	------------

AAON INC.

SPA# SV05949-000-05

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PING LIN
JOBNAME :
ISSUE DATE: 1/15/2024

	GS-M2	TR* SPECIAL ONLY	\$6,217

The expiration date for this SPA is 1/12/2025

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.