

AAON INC.

SPA# SV06141-000-06

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB  
COMPANY :  
ORIGINATOR: JOHN G GRUNDMANN  
FROM : PEYTON PATTERSON  
JOBNAME :  
ISSUE DATE: 2/19/2025

----- [ SOI TEXT ] -----

H3/V3/M2-18, 26: OMIT EXPANSION VALVE FOR DX, NO REHEAT  
STUB OUT DISTRIBUTOR FOR FIELD INSTALLED TXV

LEAD TIME ADD = NONE

----- [ SPECIAL NOTES ] -----

THIS IS A LIST PRICE ADD PER UNIT.

NOT VALID FOR M2-036 OR ANY UNIT WITH MODULATING HOT  
GAS REHEAT.

----- [ DESCRIPTION ] -----

H3/V3/M2-18, 26: OMIT EXPANSION VALVE FOR DX, NO REHEAT  
STUB OUT DISTRIBUTOR FOR FIELD INSTALLED TXV

REPLACE STANDARD COIL DOOR. NEW COIL DOOR SHOULD WILL  
NOT HAVE A LIQUID LINE CONNECTION. WILL INSTEAD HAVE A  
HOLE FOR THE DISTRIBUTOR TO STUB OUT. DISTRIBUTOR  
WILL STICK OUT PRE-CUT HOLE.

OMIT THE STANDARD TXV FOR DX COIL, PROVIDE STUB  
OUT OF CABINET FOR SUCTION AND DISTRIBUTOR FOR FIELD  
PROVIDED TXV. ONLY STRAIGHT COPPER SHOULD BE USED  
BETWEEN STUB OUT AND DISTRIBUTOR.

FIELD PROVIDED TXV WILL BE INSTALLED EXTERNAL TO THE  
CABINET

Model	Required Features	List Price
GS-ALL		\$3,250

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.