

AAON INC.

SPA# SV06940-000-03

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

----- [SOI TEXT] -----

35 KAIC SCCR

REQUIRES:

- MOP FROM 110 TO 250A
- 460/3/60 VOLTAGE

----- [SPECIAL NOTES] -----

THIS IS A LIST PRICE ADD PER UNIT.
CONFIGURE STANDARD 5KAIC SCCR FOR CORRECT PRICING.

SPA VALID FOR ANY H3/V3/M2/SB/SA THAT MEETS THE MOP
AND VOLTAGE REQUIREMENTS.

NOT VALID FOR A UNIT WITH A DISCONNECT. THIS SPA DOES
NOT PROVIDE A BREAKER OR DISCONNECT. YOU MAY REQUEST
AN ADDITIONAL SEPARATE SPA FOR AN SCCR RATED BREAKER.

ANY SPAS THAT AFFECT ELECTRICAL COMPONENTS MAY
INVALIDATE THIS SPA. CHECK WITH AAON APPLICATIONS
PRIOR TO USING THIS SPA ON YOUR ORDER.

----- [DESCRIPTION] -----

H3/V3/M2/SB/SA: 35 KAIC SCCR
- MOP FROM 110 TO 250A
- 460/3/60 VOLTAGE

*****ELECTRICAL & WIRING*****

THE CONTROL PANEL OF THE CONFIGURED UNIT SHALL BE
MODIFIED AS NECESSARY TO ACHIEVE A 35 KAIC SCCR.

*****PRODUCTION*****

USE WIRING SIZE SPECIFIED ON WIRING DIAGRAM. INCOMING
POWER WILL ENCOUNTER FUSES BEFORE POWER BLOCK.

ENSURE THAT AN ELECTRICAL ENGINEER INSPECTS THE CONTROL
PANEL FOR WIRE SIZING AND FUSE COVERS PRIOR TO
INSTALLATION IN THE UNIT.

AAON INC.

SPA# SV06940-000-03

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

Model	Required Features	List Price
GS-ALL	VOLTAGE=3;	\$9,933

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.