

AAON INC.

2425 S. YUKON AVE.
TULSA, OK 74107

SPA# SV07075-000-04

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: JOHN G GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

----- [SOI TEXT] -----

H3/V3: FACTORY INSTALLED 100A NON-FUSED DISCONNECT
EXTERNAL CONTROL BOX
(NOT NEMA RATED)

REQUIREMENTS:

UNIT CANNOT BE CONFIGURED WITH INTERNAL CONTROL BOX

----- [SPECIAL NOTES] -----

THIS SPA MAY BE ONLY APPLIED TO AN H3/V3 UNIT
CONFIGURED WITH A MEDIUM OR LARGE EXTERNAL CONTROL
BOX (F15=B OR C).

+ IF AN INTERNAL CONTROL BOX IS SELECTED, THIS SPA IS
NOT APPLICABLE.

+ IF A MEDIUM EXTERNAL CONTROL PANEL IS SELECTED THE
NEW CONTROL PANEL DIMENSIONS ARE 36" (L) X 22" (H) X
11" (W)

+ IF A LARGE EXTERNAL CONTROL PANEL IS SELECTED THE
OVERALL CONTROL PANEL DIMENSIONS REMAIN THE SAME.

UNIT MOP MUST BE LESS THAN OR EQUAL TO 100 AMPS.

A 36" CLEARANCE IS REQUIRED ON THE DISCONNECT SIDE OF
THE CONTROL PANEL. SWITCH IS INSTALLED INSIDE CONTROL
PANEL WITH A FLIP COVER.

DISCONNECT SWITCH IS NOT NEMA RATED.

----- [DESCRIPTION] -----

H3/V3: FACTORY INSTALLED 100A NON-FUSED DISCONNECT
EXTERNAL CONTROL BOX
(NOT NEMA RATED)

GENERAL

DISCONNECT WILL BE INSTALLED IN THE MEDIUM EXTENDED OR
LARGE EXTENDED EXTERNAL CONTROL PANEL.

BASE CONTROL PANEL SIZE TO MATCH CONFIGURED CONTROL
PANEL (MEDIUM TO MEDIUM EXTENDED OR LARGE TO LARGE
EXTENDED)

AAON INC.

SPA# SV07075-000-04

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEB
COMPANY :
ORIGINATOR: JOHN G GRUNDMANN
FROM : PEYTON PATTERSON
JOBNAME :
ISSUE DATE: 2/14/2025

*****ELECTRICAL*****

ADD THE FOLLOWING DISCONNECT TO THE UNIT AND SHOW ON
THE UNIT WIRING DIAGRAM:

ACP # G048710

*****MECHANICAL & BOM*****

ENSURE THAT COMPONENTS FOR PART B300-701-500 (FOR
MEDIUM EXTENDED) OR DL005405-001 FOR LARGE EXTENDED
CONTROL PANEL ARE USED IN PLACE OF THE STANDARD
CONTROL BOX

Model	Required Features	List Price
GS-ALL	NOT VALID W. INTERNAL CONTROL PANEL	\$4,573

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.