

AAON INC.

SPA# SV07395-000-05

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE  
COMPANY :  
ORIGINATOR: RACHEL MARIE GRUNDMANN  
FROM : RACHEL GRUNDMANN  
JOBNAME :  
ISSUE DATE: 1/15/2024

----- [ SOI TEXT ] -----

H3/V3/M2: DX FREEZE STAT PROTECTION - SINGLE CIRCUIT

LEAD TIME ADD = NONE

----- [ SPECIAL NOTES ] -----

THIS IS A LIST PRICE ADD PER UNIT.

VALID FOR ANY H3/V3/M2 CABINET SIZE.

THIS SPA ADDS A FREEZE STAT ATTACHED TO THE DX COIL  
OF THE AIR HANDLING UNIT.

DO NOT USE ON WATER COILS.

WHEN THE TEMPERATURE REACHES A FREEZE TEMPERATURE  
(SETPOINT +/- 5F) IT BREAKS THE 24VAC POWER. SETPOINT  
IS USER ADJUSTABLE AND MAY VARY FROM -10 DEG F TO 70  
DEG F.

----- [ DESCRIPTION ] -----

H3/V3/M2: DX FREEZE STAT PROTECTION - SINGLE CIRCUIT

\*\*\*ELECTRICAL\*\*\*  
USE PART # R10230

\*\*\*PRODUCTION\*\*\*  
POSITION THE SENSING ELEMENT FIRMLY AGAINST THE DX COIL  
SUCTION HEADER. SECURELY WRAP SENSING BULB WITH  
INSULATING FOAM TAPE.

MOUNT SWITCH WITH KNOB WHERE IT IS ACCESSIBLE FROM THE  
ACCESS DOOR.

DO NOT USE WITH WATER COILS

WIRE PER THE WIRING DIAGRAM

Model	Required Features	List Price
GS-CF	X=23 OR M2 UNIT SPECIAL=X	\$3,191

**AAON INC.**

**SPA# SV07395-000-05**

2425 S. YUKON AVE.  
TULSA, OK 74107

Ph. 918-583-2266  
Fax 918-382-6369

**GENERAL SPECIAL PRICING AUTHORIZATION**

TO : WEBSITE  
COMPANY :  
ORIGINATOR: RACHEL MARIE GRUNDMANN  
FROM : RACHEL GRUNDMANN  
JOBNAME :  
ISSUE DATE: 1/15/2024

The expiration date for this SPA is 1/12/2025

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.