

AAON INC.

SPA# SV07396-000-05

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : RACHEL GRUNDMANN
JOBNAME :
ISSUE DATE: 1/15/2024

----- [SOI TEXT] -----

H3/V3/M2: DX FREEZE STAT PROTECTION - DUAL CIRCUIT

LEAD TIME ADD = NONE

----- [SPECIAL NOTES] -----

THIS IS A LIST PRICE ADD PER UNIT.

VALID FOR ANY H3/V3/M2 CABINET SIZE CONFIGURED WITH AN
INTERTWINED COIL.

THIS SPA ADDS A FREEZE STAT ATTACHED TO THE DX COIL
OF THE AIR HANDLING UNIT. TWO FREEZE STATS PROVIDED,
ONE FOR EACH CIRCUIT.

DO NOT USE ON WATER COILS.

WHEN THE TEMPERATURE REACHES A FREEZE TEMPERATURE
(SETPOINT +/- 5F) IT BREAKS THE 24VAC POWER. SETPOINT
IS USER ADJUSTABLE AND MAY VARY FROM -10 DEG F TO 70
DEG F.

----- [DESCRIPTION] -----

H3/V3/M2: DX FREEZE STAT PROTECTION - DUAL CIRCUIT

ELECTRICAL
USE PART # R10230

PRODUCTION
POSITION THE SENSING ELEMENT FIRMLY AGAINST THE DX COIL
SUCTION HEADER ON EACH CIRCUIT. SECURELY WRAP SENSING
BULB WITH INSULATING FOAM TAPE.

MOUNT SWITCHES AND KNOB WHERE THEY ARE ACCESSIBLE FROM
THE ACCESS DOOR.

DO NOT USE WITH WATER COILS

WIRE PER THE WIRING DIAGRAM

Model	Required Features	List Price
-------	-------------------	------------

AAON INC.

SPA# SV07396-000-05

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE
COMPANY :
ORIGINATOR: RACHEL MARIE GRUNDMANN
FROM : RACHEL GRUNDMANN
JOBNAME :
ISSUE DATE: 1/15/2024

	GS-CF	X=23 OR M2 UNIT SPECIAL=X	\$3,881

The expiration date for this SPA is 1/12/2025

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.