

AAON INC.

2425 S. YUKON AVE.
TULSA, OK 74107

SPA# SP35348-000-03

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA
COMPANY :
ORIGINATOR: LARRY HONEL
FROM : TINA MCBEATH
JOBNAME :
ISSUE DATE: 10/7/2025

----- [SOI TEXT] -----

SMOKE PURGE SEQUENCE II.

----- [SPECIAL NOTES] -----

- * THIS PRICE IS PER UNIT, VALID FOR RQ, RN, & RZ UNITS.
- * SPA NOT VALID IF UNIT HAS VCCX CONTROL OPTION.
- * UNITS SELECTED WITH CHILLED WATER WILL NOT HAVE A2L MITIGATION.
- * ELECTRICAL DRAFTING: PLEASE WORK WITH PRODUCT ENGINEERING AND CONTROLS.

----- [DESCRIPTION] -----

SMOKE PURGE SEQUENCE II.

- UPON A REMOTE CONTACT CLOSURE:
- THE ECON O/A DAMPERS FULLY OPEN
- THE R/A DAMPERS CLOSE,
- THE SUPPLY FAN AND EXHAUST FANS ARE ENERGIZED. ALL OTHER FUCTIONS ARE DISABLED.
- USE BELIMO ACTUATOR

FROM FACTORY, AAON MUST WIRE THE UNIT SO THAT THE A2L MITIGATION SEQUENCE WILL TAKE PRIORITY OF THIS SMOKE PURGE SEQUENCE. IT IS UP TO LOCAL CODE AND THE AUTHORITY HAVING JURISDICTION TO DECIDE IF THE SMOKE PURGE SEQUENCE NEEDS TO TAKE PRIORITY OF THE A2L MITIGATION SEQUENCE. A JUMPER WIRE WILL NEED TO BE ADDED IN THE FIELD TO ALLOW FOR SMOKE PURGE OPERATION. WHEN SMOKE PURGE IS IN OPERATION,ALL OTHER SAFETIES ARE DISABLED.

AAON INC.

SPA# SP35348-000-03

2425 S. YUKON AVE.
TULSA, OK 74107

Ph. 918-583-2266
Fax 918-382-6369

GENERAL SPECIAL PRICING AUTHORIZATION

TO : WEBSITE SPA
COMPANY :
ORIGINATOR: LARRY HONEL
FROM : TINA MCBEATH
JOBNAME :
ISSUE DATE: 10/7/2025

Model	Required Features	List Price
GS-RN	37=X/Y/1-8	\$1,974.00

The expiration date for this SPA is 1/31/2026

Failure to include this SPA with the Order Write UP may result in incorrect order entry.

AAON, Inc. reserves the right to void or change pricing without notice.